

## 【Allowable ampacity】

Allowable ampacity (A) general wiring table 310.15 (B) (16) (17) Allowable ampacity 30°C

Size	Single insulated wires		three of them (b)	
	75°C	90°C	75°C	90°C
18 AWG	—	18	—	14
16 AWG	—	24	—	18
14 AWG	30	35	20	25
12 AWG	35	40	25	30
10 AWG	50	55	35	40
8 AWG	70	80	50	55
6 AWG	95	105	65	75
4 AWG	125	140	85	95
2 AWG	170	190	115	130
1 AWG	195	220	130	145
1/0 AWG	230	260	150	170
2/0 AWG	265	300	175	195
3/0 AWG	310	350	200	225
4/0 AWG	360	405	230	260
300MCM	445	500	285	320
400MCM	545	615	335	380
500MCM	620	700	380	430

NFPA79 table 12.5.1 Allowable ampacity 30°C

Size	three of them (b)	
	75°C	90°C
30 AWG	0.5	0.5
28 AWG	0.8	0.8
26 AWG	1	1
24 AWG	2	2
22 AWG	3	3
20 AWG	5	5
18 AWG	7	14
16 AWG	10	18
14 AWG	20	25
12 AWG	25	30
10 AWG	35	40
8 AWG	50	55
6 AWG	65	75
4 AWG	85	95
2 AWG	115	130
1 AWG	130	150
1/0 AWG	150	170
2/0 AWG	175	195
3/0 AWG	200	225
4/0 AWG	230	260
300 MCM	285	320
400 MCM	335	380
500 MCM	380	430

## 【Ambient temperature correction factor】

Extract it than table 310.15 (B) (2) (a)

Ambient temperature (°C)	Temperature rating of conductor	
	75°C	90°C
10以下	1.20	1.15
11~15	1.15	1.12
16~20	1.11	1.08
21~25	1.05	1.04
26~30	1.00	1.00
31~35	0.94	0.96
36~40	0.88	0.91
41~45	0.82	0.87
46~50	0.75	0.82
51~55	0.67	0.76
56~60	0.58	0.71
61~65	0.47	0.65
66~70	0.33	0.58
71~75	—	0.50
76~80	—	0.41
81~85	—	0.29

NFPA79 table 12.5.5 (a)

Ambient temperature (°C)	Temperature rating	
	75°C	90°C
21~25	1.05	1.04
26~30	1	1
31~35	0.94	0.96
36~40	0.88	0.91
41~45	0.82	0.87
46~50	0.75	0.82
51~55	0.67	0.76
56~60	0.58	0.71
61~70	0.33	0.58
71~80	—	0.41

## 【Current reduction rate that adapt wiring road or more than 4 lines cable's conductor】

Extract it than table 310.15 (B) (3) (a)

Number of conductor	Current reduction rate (%) as above table (b)
4~6	80
7~9	70
10~20	50
21~30	45
31~40	40
41以上	35

NFPA79 Extract it than table 12.5.5 (b)

Number of conductor	Current reduction rate (%) as above table (b)
4~6	80
7~9	70
10~20	50
21~30	45
31~40	40
41以上	35

## 【Adjustment factor at many articles in the air construction】

Adjustment factor adapted 1 to 12 line at many articles in the air construction Extract it than JCS 0168-1 : 2004

Line number	Adjustment factor of current $\eta_0$				
	1	2	3	6	4
Layout					
Space of center					
S = $d_s$	1.00	0.85	0.80	0.70	0.70
S = $2d_s$		0.95	0.95	0.90	0.90
S = $3d_s$		1.00	1.00	0.95	0.95

Line number	Adjustment factor of current $\eta_0$			
	6	8	9	12
Layout				
Space of center				
S = $d_s$	0.60	—	—	—
S = $2d_s$	0.90	0.85	0.80	0.80
S = $3d_s$	0.95	0.90	0.85	0.85

Adjustment factor at many articles in the air construction of other than above table

Space of center layout	Adjustment factor of current $\eta_0$										
	Step (n)	2					3				
	Column (m)	7~20	4	5	6	7	8~20	3	4	5	6
S = $d_s$	0.70	0.60	0.56	0.53	0.51	0.50	0.48	0.41	0.37	0.34	0.32
S = $2d_s$	0.80	—	0.73	0.72	0.71	0.70	—	—	0.68	0.66	0.65

Space of center layout	Adjustment factor of current $\eta_0$						
	Step (n)	3					
	Column (m)	8	9~10	11~12	13~15	16~19	20
S = $d_s$	0.31	0.30	0.30	0.30	0.30	0.30	
S = $2d_s$	0.65	0.64	0.63	0.62	0.61	0.60	

Moved bending test is carried out along the Electrical Appliance and Material Safety Law (Appendix first Supplementary Table twenty-sixth). Method will be as follows. Mount a sample of about 3m taken from the finished product. This according to the type of the cable Table 2, (with the moving carriage fitted with a diameter pulleys) in Table 2 attached in FIG.6. At that time, the portion between the pulleys to move the bending test apparatus is set to be horizontal. Then, hang a weight of mass shown in <Table 2> at both ends thereof. At a rate of per second about 0.33m to move the truck, reciprocating a distance of more than 0.5m to the left or right. At that time, not rise to a short circuit between the lines, no crack about surface of the insulation and the exterior, and other abnormalities that there is no.

Figure.6




Table.2

Sample	Mass of sinker	Diameter of pulley
Power cable	1.5kg	120mm
Signal cable	1.0kg	80mm